

# PTI 2,5 - Installation terminal block



3213968

<https://www.phoenixcontact.com/au/products/3213968>

Please be informed that the data shown in this PDF document is generated from our online catalog. Please find the complete data in the user documentation. Our general terms of use for downloads are valid.



Installation terminal block, nom. voltage: 800 V, nominal current: 24 A, Push-in connection, 1 level, Rated cross section: 2.5 mm<sup>2</sup>, cross section: 0.14 mm<sup>2</sup> - 4 mm<sup>2</sup>, mounting type: NS 35/7,5, NS 35/15, color: gray

## Your advantages

- Compatible with all Phoenix Contact installation terminal blocks
- Each terminal point can be clearly labeled and easily recognized in every terminal block mounting position
- As well as the testing facility in the function shaft, each terminal point has a test contact
- Compact design tailored to distribution boards
- The new Push-in connection technology enables easy, direct insertion of solid and stranded conductors with ferrules with a cross section of 0.34 mm<sup>2</sup> or higher

## Commercial data

|                                      |                    |
|--------------------------------------|--------------------|
| Item number                          | 3213968            |
| Packing unit                         | 50 pc              |
| Minimum order quantity               | 50 pc              |
| Sales key                            | BE2251             |
| Product key                          | BE2251             |
| Catalog page                         | Page 90 (C-1-2019) |
| GTIN                                 | 4046356609326      |
| Weight per piece (including packing) | 7.315 g            |
| Weight per piece (excluding packing) | 7.203 g            |
| Customs tariff number                | 85369010           |
| Country of origin                    | PL                 |

# PTI 2,5 - Installation terminal block

3213968

<https://www.phoenixcontact.com/au/products/3213968>



## Technical data

### Notes

#### General

|      |                                                                                                                                                                                                                     |
|------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Note | When establishing a connection on the open housing side of a feed-through modular terminal block of the same series and size, the block must be provided with a cover if the expected insulation voltage is >320 V. |
|      | The max. load current must not be exceeded by the total current of all connected conductors.                                                                                                                        |

### Product properties

|                       |                             |
|-----------------------|-----------------------------|
| Product type          | Installation terminal block |
| Number of connections | 2                           |
| Number of rows        | 1                           |
| Potentials            | 1                           |

#### Insulation characteristics

|                      |     |
|----------------------|-----|
| Overvoltage category | III |
| Degree of pollution  | 3   |

### Electrical properties

|                                                 |        |
|-------------------------------------------------|--------|
| Rated surge voltage                             | 8 kV   |
| Maximum power dissipation for nominal condition | 1.02 W |
| Current carrying capacity of the neutral busbar | 140 A  |

### Connection data

|                                 |                     |
|---------------------------------|---------------------|
| Number of connections per level | 2                   |
| Nominal cross section           | 2.5 mm <sup>2</sup> |

#### 1 level

|                                                                                           |                                                       |
|-------------------------------------------------------------------------------------------|-------------------------------------------------------|
| Stripping length                                                                          | 8 mm ... 10 mm                                        |
| Internal cylindrical gage                                                                 | A3                                                    |
| Connection in acc. with standard                                                          | IEC 60947-7-1                                         |
| Conductor cross section rigid                                                             | 0.14 mm <sup>2</sup> ... 4 mm <sup>2</sup>            |
| Cross section AWG                                                                         | 26 ... 12 (converted acc. to IEC)                     |
| Conductor cross section flexible                                                          | 0.14 mm <sup>2</sup> ... 4 mm <sup>2</sup>            |
| Conductor cross section, flexible [AWG]                                                   | 26 ... 12 (converted acc. to IEC)                     |
| Conductor cross-section flexible (ferrule without plastic sleeve)                         | 0.14 mm <sup>2</sup> ... 2.5 mm <sup>2</sup>          |
| Flexible conductor cross section (ferrule with plastic sleeve)                            | 0.14 mm <sup>2</sup> ... 2.5 mm <sup>2</sup>          |
| 2 conductors with the same cross section, flexible, with TWIN ferrule with plastic sleeve | 0.5 mm <sup>2</sup>                                   |
| Nominal current                                                                           | 24 A                                                  |
| Maximum load current                                                                      | 24 A (with 4 mm <sup>2</sup> conductor cross section) |
| Nominal voltage                                                                           | 800 V                                                 |

# PTI 2,5 - Installation terminal block



3213968

<https://www.phoenixcontact.com/au/products/3213968>

|                       |                     |
|-----------------------|---------------------|
| Nominal cross section | 2.5 mm <sup>2</sup> |
|-----------------------|---------------------|

1 level Connection cross sections directly pluggable

|                                                                   |                                              |
|-------------------------------------------------------------------|----------------------------------------------|
| Conductor cross section rigid                                     | 0.34 mm <sup>2</sup> ... 4 mm <sup>2</sup>   |
| Conductor cross-section flexible (ferrule without plastic sleeve) | 0.34 mm <sup>2</sup> ... 2.5 mm <sup>2</sup> |
| Flexible conductor cross section (ferrule with plastic sleeve)    | 0.34 mm <sup>2</sup> ... 2.5 mm <sup>2</sup> |

## Dimensions

|                    |         |
|--------------------|---------|
| Width              | 5.2 mm  |
| End cover width    | 2.2 mm  |
| Height             | 59.5 mm |
| Depth              | 42.5 mm |
| Depth on NS 35/7,5 | 44 mm   |
| Depth on NS 35/15  | 51.5 mm |

## Material specifications

|                                                                         |                 |
|-------------------------------------------------------------------------|-----------------|
| Color                                                                   | gray (RAL 7042) |
| Flammability rating according to UL 94                                  | V0              |
| Insulating material group                                               | I               |
| Insulating material                                                     | PA              |
| Static insulating material application in cold                          | -60 °C          |
| Temperature index of insulation material (DIN EN 60216-1 (VDE 0304-21)) | 125 °C          |
| Relative insulation material temperature index (Elec., UL 746 B)        | 130 °C          |
| Fire protection for rail vehicles (DIN EN 45545-2) R22                  | HL 1 - HL 3     |
| Fire protection for rail vehicles (DIN EN 45545-2) R23                  | HL 1 - HL 3     |
| Fire protection for rail vehicles (DIN EN 45545-2) R24                  | HL 1 - HL 3     |
| Fire protection for rail vehicles (DIN EN 45545-2) R26                  | HL 1 - HL 3     |
| Calorimetric heat release NFPA 130 (ASTM E 1354)                        | 27,5 MJ/kg      |
| Surface flammability NFPA 130 (ASTM E 162)                              | passed          |
| Specific optical density of smoke NFPA 130 (ASTM E 662)                 | passed          |
| Smoke gas toxicity NFPA 130 (SMP 800C)                                  | passed          |

## Electrical tests

### Surge voltage test

|                       |             |
|-----------------------|-------------|
| Test voltage setpoint | 9.8 kV      |
| Result                | Test passed |

### Temperature-rise test

|                                                |                                |
|------------------------------------------------|--------------------------------|
| Requirement temperature-rise test              | Increase in temperature ≤ 45 K |
| Result                                         | Test passed                    |
|                                                | Test passed                    |
| Short-time withstand current 4 mm <sup>2</sup> | 0.48 kA                        |
| Result                                         | Test passed                    |

# PTI 2,5 - Installation terminal block



3213968

<https://www.phoenixcontact.com/au/products/3213968>

## Power-frequency withstand voltage

|                       |             |
|-----------------------|-------------|
| Test voltage setpoint | 2 kV        |
| Result                | Test passed |

## Mechanical properties

### Mechanical data

|                 |     |
|-----------------|-----|
| Open side panel | Yes |
|-----------------|-----|

## Mechanical tests

### Mechanical strength

|        |             |
|--------|-------------|
| Result | Test passed |
|--------|-------------|

### Attachment on the carrier

|                         |             |
|-------------------------|-------------|
| DIN rail/fixing support | NS 35       |
| Test force setpoint     | 1 N         |
| Result                  | Test passed |

### Test for conductor damage and slackening

|                                |                               |
|--------------------------------|-------------------------------|
| Rotation speed                 | 10 (+/- 2) rpm                |
| Revolutions                    | 135                           |
| Conductor cross section/weight | 0.14 mm <sup>2</sup> / 0.2 kg |
|                                | 2.5 mm <sup>2</sup> / 0.7 kg  |
|                                | 4 mm <sup>2</sup> / 0.9 kg    |
| Result                         | Test passed                   |

## Environmental and real-life conditions

### Aging

|                    |             |
|--------------------|-------------|
| Temperature cycles | 192         |
| Result             | Test passed |

### Needle-flame test

|                  |             |
|------------------|-------------|
| Time of exposure | 30 s        |
| Result           | Test passed |

### Oscillation/broadband noise

|                        |                                                |
|------------------------|------------------------------------------------|
| Specification          | DIN EN 50155 (VDE 0115-200):2018-05            |
| Spectrum               | Long life test category 2, bogie-mounted       |
| Frequency              | $f_1 = 5 \text{ Hz}$ to $f_2 = 250 \text{ Hz}$ |
| ASD level              | 6.12 (m/s <sup>2</sup> ) <sup>2</sup> /Hz      |
| Acceleration           | 3.12g                                          |
| Test duration per axis | 5 h                                            |
| Test directions        | X-, Y- and Z-axis                              |
| Result                 | Test passed                                    |

### Shocks

# PTI 2,5 - Installation terminal block



3213968

<https://www.phoenixcontact.com/au/products/3213968>

|                                |                                     |
|--------------------------------|-------------------------------------|
| Specification                  | DIN EN 50155 (VDE 0115-200):2008-03 |
| Pulse shape                    | Half-sine                           |
| Acceleration                   | 5g                                  |
| Shock duration                 | 30 ms                               |
| Number of shocks per direction | 3                                   |
| Test directions                | X-, Y- and Z-axis (pos. and neg.)   |
| Result                         | Test passed                         |

## Ambient conditions

|                                          |                                                                                                                              |
|------------------------------------------|------------------------------------------------------------------------------------------------------------------------------|
| Ambient temperature (operation)          | -60 °C ... 110 °C (Operating temperature range incl. self-heating; for max. short-term operating temperature, see RTI Elec.) |
| Ambient temperature (storage/transport)  | -25 °C ... 60 °C (for a short time, not exceeding 24 h, -60 °C to +70 °C)                                                    |
| Ambient temperature (assembly)           | -5 °C ... 70 °C                                                                                                              |
| Ambient temperature (actuation)          | -5 °C ... 70 °C                                                                                                              |
| Permissible humidity (operation)         | 20 % ... 90 %                                                                                                                |
| Permissible humidity (storage/transport) | 30 % ... 70 %                                                                                                                |

## Standards and regulations

|                                  |               |
|----------------------------------|---------------|
| Connection in acc. with standard | IEC 60947-7-1 |
|----------------------------------|---------------|

## Mounting

|               |           |
|---------------|-----------|
| Mounting type | NS 35/7,5 |
|               | NS 35/15  |

# PTI 2,5 - Installation terminal block

3213968

<https://www.phoenixcontact.com/au/products/3213968>



## Drawings

Circuit diagram



# PTI 2,5 - Installation terminal block



3213968

<https://www.phoenixcontact.com/au/products/3213968>

## Approvals

To download certificates, visit the product detail page: <https://www.phoenixcontact.com/au/products/3213968>

|                                    |                       |                       |                   |                             |
|------------------------------------|-----------------------|-----------------------|-------------------|-----------------------------|
| <b>CSA</b><br>Approval ID: 2030668 |                       |                       |                   |                             |
|                                    | Nominal voltage $U_N$ | Nominal current $I_N$ | Cross section AWG | Cross section $\text{mm}^2$ |
| Use group B                        |                       |                       |                   |                             |
|                                    | 600 V                 | 20 A                  | 26 - 12           | -                           |
| Use group C                        |                       |                       |                   |                             |
|                                    | 600 V                 | 20 A                  | 26 - 12           | -                           |

|                                                  |                       |                       |                   |                             |
|--------------------------------------------------|-----------------------|-----------------------|-------------------|-----------------------------|
| <b>IECEE CB Scheme</b><br>Approval ID: DE1-62969 |                       |                       |                   |                             |
|                                                  | Nominal voltage $U_N$ | Nominal current $I_N$ | Cross section AWG | Cross section $\text{mm}^2$ |
|                                                  | 800 V                 | 24 A                  | -                 | 0.14 - 4                    |

|                                                 |  |  |  |  |
|-------------------------------------------------|--|--|--|--|
| <b>EAC</b><br>Approval ID: RU C-DE.BL08.B.00644 |  |  |  |  |
|-------------------------------------------------|--|--|--|--|

|                                                |                       |                       |                   |                             |
|------------------------------------------------|-----------------------|-----------------------|-------------------|-----------------------------|
| <b>cULus Recognized</b><br>Approval ID: E60425 |                       |                       |                   |                             |
|                                                | Nominal voltage $U_N$ | Nominal current $I_N$ | Cross section AWG | Cross section $\text{mm}^2$ |
| Use group B                                    |                       |                       |                   |                             |
|                                                | 600 V                 | 20 A                  | 26 - 12           | -                           |
| Use group C                                    |                       |                       |                   |                             |
|                                                | 600 V                 | 20 A                  | 26 - 12           | -                           |
| Use group D                                    |                       |                       |                   |                             |
|                                                | 600 V                 | 5 A                   | 26 - 12           | -                           |

|                                                        |                       |                       |                   |                             |
|--------------------------------------------------------|-----------------------|-----------------------|-------------------|-----------------------------|
| <b>VDE Zeichengenehmigung</b><br>Approval ID: 40040549 |                       |                       |                   |                             |
|                                                        | Nominal voltage $U_N$ | Nominal current $I_N$ | Cross section AWG | Cross section $\text{mm}^2$ |
|                                                        | 800 V                 | 24 A                  | -                 | 0.14 - 4                    |

|                                       |  |  |  |  |
|---------------------------------------|--|--|--|--|
| <b>DNV</b><br>Approval ID: TAE00001BU |  |  |  |  |
|---------------------------------------|--|--|--|--|

|                                               |  |  |  |  |
|-----------------------------------------------|--|--|--|--|
| <b>EAC</b><br>Approval ID: KZ7500651131219505 |  |  |  |  |
|-----------------------------------------------|--|--|--|--|

# PTI 2,5 - Installation terminal block

3213968

<https://www.phoenixcontact.com/au/products/3213968>



# PTI 2,5 - Installation terminal block



3213968

<https://www.phoenixcontact.com/au/products/3213968>

## Classifications

### ECLASS

|             |          |
|-------------|----------|
| ECLASS-13.0 | 27250110 |
| ECLASS-15.0 | 27250110 |

### ETIM

|          |          |
|----------|----------|
| ETIM 9.0 | EC001329 |
|----------|----------|

### UNSPSC

|             |          |
|-------------|----------|
| UNSPSC 21.0 | 39121400 |
|-------------|----------|

# PTI 2,5 - Installation terminal block



3213968

<https://www.phoenixcontact.com/au/products/3213968>

## Environmental product compliance

|                                         |                                          |
|-----------------------------------------|------------------------------------------|
| EU RoHS                                 |                                          |
| Fulfills EU RoHS substance requirements | Yes, No exemptions                       |
| China RoHS                              |                                          |
| Environment friendly use period (EFUP)  | EFUP-E                                   |
|                                         | No hazardous substances above the limits |
| EU REACH SVHC                           |                                          |
| REACH candidate substance (CAS No.)     | No substance above 0.1 wt%               |
| EF3.0 Climate Change                    |                                          |
| CO2e kg                                 | 0.042 kg CO2e                            |

Phoenix Contact 2025 © - all rights reserved  
<https://www.phoenixcontact.com>

PHOENIX CONTACT PTY Ltd  
Unit 7, 2-8 South Street  
Rydalmere NSW 2116  
1300 786 411  
[customerservice@phoenixcontact.com.au](mailto:customerservice@phoenixcontact.com.au)